

FAB ZONA OESTE MAIS SANEAMENTO - ÁREA DE PLANEJAMENTO 05
QUALIDADE DO SERVIÇO DE ESGOTAMENTO SANITÁRIO
Ofício MA/CGCA/CLA/GLA-4 Nº 1029 / 2016

Unidades	Ano de Referência: 2019	Julho							Agosto							
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	1	40 mg/L	40 mg/L	30 mg/L	2mg/L	5 - 9	< 40	1	40 mg/L	40 mg/L	30 mg/L	2mg/L
ETE Deodoro	-	7,0	23,0	0,0	9,5	14,0	<5	<0,1	6,0	28,0	0,0	14,5	7,4	<5	<0,1	
ETE Sepetiba	-	7,0	26,0	0,0	6,0	0,8	<5	<0,1	7,0	25,8	0,0	8,0	5,0	<5	<0,1	
ETE Pedra de Guaratiba	-	7,0	27,0	0,5	39,0	16,7	<5	<0,1	6,5	27,0	0,5	33,0	17,5	<5	1,7	
ETE Nova Cidade	-	6,0	25,0	0,0	16,0	16,2	<5	<0,1	6,4	25,0	0,0	9,0	6,0	<5	<0,1	
ETE Vila do Céu	-	7,0	24,0	0,0	3,0	10,0	<5	<0,1	6,4	25,3	0,1	5,0	6,0	<5	<0,1	
ETE Vilar Carioca	-	6,0	23,0	0,0	2,0	11,0	<5	<0,1	6,0	23,0	0,0	3,0	2,0	<5	<0,1	
ETE Vila Catiri	-	6,0	29,0	0,0	7,0	3,0	<5	<0,1	6,4	25,8	0,0	3,0	1,5	<5	<0,1	
ETE Ana Gonzaga	-	6,7	26,3	0,0	8,0	0,8	<5	<0,1	6,1	20,5	0,0	1,0	0,8	<5	<0,1	
ETE Vila Nova Sepetiba	-	7,0	25,0	0,0	14,0	7,7	<5	<0,1	6,3	18,5	0,0	7,0	7,5	<5	<0,1	
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	2	180 mg/L	180 mg/L	30 mg/L	4mg/L	5 - 9	< 40	2	180 mg/L	180 mg/L	30 mg/L	4mg/L
ETE Cidade das Crianças	-	6,2	24,0	0,0	16,0	22,0	<5	<0,1	6,1	26,0	0,0	5,0	3,5	<5	<0,1	
ETE Palmares	-	7,0	24,0	0,0	20,0	29,5	<5	<0,1	7,0	23,5	0,0	18,0	10,5	<5	<0,1	
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	2	180 mg/L	180 mg/L	40 mg/L	4mg/L	5 - 9	< 40	2	180 mg/L	180 mg/L	40 mg/L	4mg/L
ETE Coqueiro	-	6,0	25,8	0,4	30,0	26,7	<5	0,4	6,5	20,8	0,4	15,0	35,2	<5	0,5	
ETE Vila Kennedy	-	6,0	25,0	0,5	70,0	35,5	<5	0,5	6,0	24,8	0,2	20,0	24,3	<5	<0,1	
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	1	60 mg/L	60 mg/L	30 mg/L	2mg/L	5 - 9	< 40	1	60 mg/L	60 mg/L	30 mg/L	2mg/L
ETE Areal	-	6,4	27,0	0,0	3,0	4,5	<5	<0,1	6,0	26,0	0,0	2,0	0,8	<5	<0,1	
ETE Piaí	-	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	
ETE Nova Sepetiba V	-	6,0	25,0	0,0	44,0	16,0	<5	<0,1	7,0	27,0	0,0	29,0	32,0	<5	1,7	
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	2	100 mg/L	100 mg/L	40 mg/L	4mg/L	5 - 9	< 40	2	100 mg/L	100 mg/L	40 mg/L	4mg/L
ETE Vila João Lopes	-	7,0	29,1	1,6	21,0	30,0	<5	1,3	6,0	28,0	1,6	78,0	40,0	<5	2,8	
ETE São Fernando	-	7,0	25,0	0,3	58,0	24,0	<5	<0,1	7,0	24,0	0,2	26,0	21,1	<5	2,0	



FAB ZONA OESTE MAIS SANEAMENTO - ÁREA DE PLANEJAMENTO 05

QUALIDADE DO SERVIÇO DE ESGOTAMENTO SANITÁRIO

Ofício MA/CGCA/CLA/GLA-4 Nº 1029 / 2016

Unidades	Ano de Referência: 2019		Setembro						Outubro							
	Parâmetros		pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
	Limites		5 - 9	< 40	1	40 mg/L	40 mg/L	30 mg/L	2mg/L	5 - 9	< 40	1	40 mg/L	40 mg/L	30 mg/L	2mg/L
ETE Deodoro	-		6,2	28,0	0,0	9,5	7,5	<5	<0,1	6,0	27,5	0,0	20,5	7,3	<5	<0,1
ETE Sepetiba	-		7,0	24,3	0,0	9,0	6,5	<5	<0,1	7,0	25,0	0,0	8,0	0,8	<5	<0,1
ETE Pedra de Guaratiba	-		7,0	27,0	0,3	37,0	50,0	<5	1,4	7,0	25,0	0,4	27,0	27,1	<5	1,0
ETE Nova Cidade	-		6,5	23,0	0,0	7,0	9,0	<5	<0,1	6,0	26,0	0,0	17,0	6,0	<5	<0,1
ETE Vila do Céu	-		7,0	25,0	0,1	1,0	2,0	<5	<0,1	7,0	25,0	0,1	6,0	3,0	<5	<0,1
ETE Vilar Carioca	-		6,0	25,0	0,0	7,0	10,5	<5	<0,1	6,0	25,0	0,0	11,0	3,0	<5	<0,1
ETE Vila Catiri	-		7,0	23,5	0,0	6,0	3,0	<5	<0,1	6,9	28,0	0,0	7,0	3,3	<5	<0,1
ETE Ana Gonzaga	-		6,4	24,5	0,0	4,0	19,6	<5	<0,1	6,2	25,3	0,0	3,0	6,0	<5	<0,1
ETE Vila Nova Sepetiba	-		6,7	21,5	0,0	5,0	0,8	<5	<0,1	6,6	24,0	0,0	7,0	2,5	<5	<0,1
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	2	180 mg/L	180 mg/L	30 mg/L	4mg/L	5 - 9	< 40	2	180 mg/L	180 mg/L	30 mg/L	4mg/L
ETE Cidade das Crianças	-		6,2	22,0	0,0	4,0	3,0	<5	<0,1	7,0	27,0	0,0	0,8	5,0	<5	<0,1
ETE Palmares	-		7,0	23,0	0,0	21,0	5,4	<5	<0,1	5,4	25,0	0,0	6,0	0,8	<5	<0,1
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	2	180 mg/L	180 mg/L	40 mg/L	4mg/L	5 - 9	< 40	2	180 mg/L	180 mg/L	40 mg/L	4mg/L
ETE Coqueiro	-		7,0	27,0	0,4	28,0	23,1	5,0	0,6	7,0	24,0	0,3	29,0	9,6	<5	<0,1
ETE Vila Kennedy	-		7,0	22,8	0,0	27,0	58,8	<5	<0,1	6,0	26,0	0,0	35,0	12,1	<5	<0,1
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	1	60 mg/L	60 mg/L	30 mg/L	2mg/L	5 - 9	< 40	1	60 mg/L	60 mg/L	30 mg/L	2mg/L
ETE Areal	-		6,4	26,0	0,0	4,0	15,0	<5	<0,1	6,0	26,0	0,0	5,0	6,0	<5	<0,1
ETE Piaí	-		6,4	24,0	0,0	20,0	12,5	<5	<0,1	6,5	28,0	0,2	22,0	3,0	<5	<0,1
ETE Nova Sepetiba V	-		6,9	25,5	0,0	29,0	25,3	<5	0,7	7,0	26,0	0,0	31,0	22,0	23,0	2,0
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	2	100 mg/L	100 mg/L	40 mg/L	4mg/L	5 - 9	< 40	2	100 mg/L	100 mg/L	40 mg/L	4mg/L
ETE Vila João Lopes	-		6,0	29,0	1,8	60,0	41,9	13,0	3,4	6,0	29,0	1,6	25,0	29,4	8,0	2,3
ETE São Fernando	-		6,0	25,0	0,3	63,0	62,9	<5	2,7	7,0	27,0	0,1	68,0	20,0	<5	2,0

Unidades	Ano de Referência: 2019		Novembro						Dezembro							
	Parâmetros		pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
	Limites		5 - 9	< 40	1	40 mg/L	40 mg/L	30 mg/L	2mg/L	5 - 9	< 40	1	40 mg/L	40 mg/L	30 mg/L	2mg/L
ETE Deodoro	-		6,8	25,0	0,0	4,5	6,7	<5	<0,1	6,0	27,0	0,0	9,5	0,8	<5	<0,1
ETE Sepetiba	-		6,0	27,0	0,0	7,0	0,8	<5	<0,1	7,0	27,0	0,0	4,0	3,5	<5	<0,1
ETE Pedra de Guaratiba	-		7,0	27,0	0,4	47,0	12,7	<5	2,7	7,0	27,0	0,0	4,0	0,8	<5	<0,1
ETE Nova Cidade	-		6,7	26,0	0,0	8,0	14,7	<5	<0,1	6,6	30,0	0,0	4,0	1,5	<5	<0,1
ETE Vila do Céu	-		6,5	26,0	0,1	5,0	5,1	<5	<0,1	7,0	25,0	0,0	5,0	7,5	<5	<0,1
ETE Vilar Carioca	-		6,0	21,0	0,0	7,0	19,7	<5	0,5	6,0	22,0	0,0	8,0	0,8	<5	<0,1
ETE Vila Catiri	-		7,0	26,0	0,0	4,0	3,0	<5	<0,1	6,2	26,0	0,0	3,0	13,6	<5	<0,1
ETE Ana Gonzaga	-		6,9	27,0	0,0	4,0	3,6	<5	<0,1	6,0	31,0	0,0	18,0	7,5	<5	1,6
ETE Vila Nova Sepetiba	-		7,0	29,0	0,0	5,0	11,0	<5	<0,1	6,3	27,0	0,0	8,0	0,8	<5	<0,1
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	2	180 mg/L	180 mg/L	30 mg/L	4mg/L	5 - 9	< 40	2	180 mg/L	180 mg/L	30 mg/L	4mg/L
ETE Cidade das Crianças	-		6,3	29,0	0,0	5,0	1,5	<5	<0,1	5,5	26,0	0,0	41,0	56,5	<5	<0,1
ETE Palmares	-		6,0	25,0	0,0	6,0	18,1	<5	<0,1	6,0	24,0	0,0	15,8	14,0	<5	<0,1
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	2	180 mg/L	180 mg/L	40 mg/L	4mg/L	5 - 9	< 40	2	180 mg/L	180 mg/L	40 mg/L	4mg/L
ETE Coqueiro	-		7,0	25,0	0,4	55,0	54,0	7,0	1,4	7,0	26,0	0,3	43,0	18,5	<5	1,2
ETE Vila Kennedy	-		6,0	24,0	0,0	18,0	20,5	<5	<0,1	5,9	26,0	0,0	26,0	9,3	<5	<0,1
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	1	60 mg/L	60 mg/L	30 mg/L	2mg/L	5 - 9	< 40	1	60 mg/L	60 mg/L	30 mg/L	2mg/L
ETE Areal	-		6,0	25,0	0,0	6,0	0,8	<5	<0,1	7,0	29,0	0,0	8,0	0,8	<5	<0,1
ETE Piaí	-		6,4	25,0	0,0	8,0	17,0	<5	<0,1	6,8	27,0	0,4	20,0	22,4	<5	<0,1
ETE Nova Sepetiba V	-		6,1	28,0	0,0	13,0	44,1	<5	<0,1	6,7	26,0	0,0	12,0	8,0	<5	<0,1
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	2	100 mg/L	100 mg/L	40 mg/L	4mg/L	5 - 9	< 40	2	100 mg/L	100 mg/L	40 mg/L	4mg/L
ETE Vila João Lopes	-		6,0	29,0	1,8	38,0	15,3	<5	1,6	6,0	29,0	1,7	59,0	32,4	<5	2,4
ETE São Fernando	-		7,0	27,0	0,2	39,0	33,0	<5	3,1	7,0	29,0	0,3	69,0	40,0	12,0	2,3