

FAB ZONA OESTE MAIS SANEAMENTO - ÁREA DE PLANEJAMENTO 05
QUALIDADE DO SERVIÇO DE ESGOTAMENTO SANITÁRIO
Ofício MA/CGCA/CLA/GLA-4 Nº 1029 / 2016

Unidades	Ano de Referência: 2020		Julho						Agosto						
	Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
	Limites	5 - 9	< 40	1	40 mg/L	40 mg/L	30 mg/L	2mg/L	5 - 9	< 40	1	40 mg/L	40 mg/L	30 mg/L	2mg/L
ETE Deodoro	-	6,1	25,5	0,0	15,3	10,0	10,0	0,2	6,0	25,2	0,1	17,3	12,0	10,0	0,2
ETE Sepetiba	-	6,1	24,5	0,0	22,0	22,5	10,0	0,1	6,3	23,9	0,0	17,5	14,5	10,0	0,1
ETE Pedra de Guaratiba	-	7,0	24,7	0,0	3,5	11,0	10,0	0,1	7,0	24,8	0,0	10,0	15,0	10,0	0,1
ETE Nova Cidade	-	5,5	25,5	0,0	9,0	10,5	10,0	0,1	5,3	25,5	0,0	16,0	12,0	10,0	0,1
ETE Vila do Céu	-	6,5	22,8	0,0	10,5	10,0	10,0	0,2	6,0	22,0	0,0	8,0	10,0	10,0	0,1
ETE Vilar Carioca	-	6,0	26,0	0,0	11,5	10,0	10,0	0,1	6,0	25,0	0,0	6,5	10,0	10,0	0,1
ETE Vila Catiri	-	6,5	24,7	0,0	4,0	10,0	10,0	0,1	6,5	24,3	0,0	4,0	10,0	10,0	0,1
ETE Ana Gonzaga	-	6,0	24,7	0,0	14,0	10,0	10,0	0,2	6,0	24,5	0,0	7,0	15,0	10,0	0,6
ETE Vila Nova Sepetiba	-	6,9	27,0	0,1	7,0	11,0	10,0	0,1	6,8	25,0	0,0	10,0	18,0	10,0	0,1
	Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
	Limites	5 - 9	< 40	2	180 mg/L	180 mg/L	30 mg/L	4mg/L	5 - 9	< 40	2	180 mg/L	180 mg/L	30 mg/L	4mg/L
ETE Cidade das Crianças	-	5,7	23,5	0,0	4,0	16,0	10,0	0,1	5,6	24,4	0,0	6,0	21,0	10,0	0,1
ETE Palmares	-	6,0	25,2	0,1	45,5	44,5	10,0	1,8	6,0	25,5	0,0	48,5	36,5	10,0	0,5
	Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
	Limites	5 - 9	< 40	2	180 mg/L	180 mg/L	40 mg/L	4mg/L	5 - 9	< 40	2	180 mg/L	180 mg/L	40 mg/L	4mg/L
ETE Coqueiro	-	6,0	22,4	0,1	86,0	49,0	10,0	3,8	6,0	24,8	0,1	37,0	31,0	10,0	3,6
ETE Vila Kennedy	-	5,4	23,2	0,0	17,0	11,5	10,0	0,1	5,0	22,5	0,0	16,0	14,0	10,0	0,3
	Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
	Limites	5 - 9	< 40	1	60 mg/L	60 mg/L	30 mg/L	2mg/L	5 - 9	< 40	1	60 mg/L	60 mg/L	30 mg/L	2mg/L
ETE Areal	-	5,9	25,2	0,0	2,0	10,0	10,0	0,1	5,5	24,5	0,0	11,0	10,0	10,0	0,1
ETE Piaí	-	6,7	24,5	0,0	14,0	10,0	10,0	0,1	6,7	23,8	0,0	6,0	16,0	10,0	0,1
ETE Nova Sepetiba V	-	6,0	26,1	0,0	2,0	10,0	10,0	0,1	6,0	26,1	0,0	14,0	11,0	10,0	0,1
	Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
	Limites	5 - 9	< 40	2	100 mg/L	100 mg/L	40 mg/L	4mg/L	5 - 9	< 40	2	100 mg/L	100 mg/L	40 mg/L	4mg/L
ETE Vila João Lopes	-	6,2	27,7	0,7	95,0	38,0	13,0	2,5	6,4	26,2	0,4	82,0	43,0	10,0	3,9
ETE São Fernando	-	6,2	24,5	0,4	41,0	54,0	10,0	3,8	6,7	23,9	1,5	57,0	79,0	10,0	2,7

Unidades	Ano de Referência: 2020		Setembro						Outubro							
	Parâmetros		pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
	Limites		5 - 9	< 40	1	40 mg/L	40 mg/L	30 mg/L	2mg/L	5 - 9	< 40	1	40 mg/L	40 mg/L	30 mg/L	2mg/L
ETE Deodoro	-		6,0	26,9	0,0	11,5	16,5	10,0	0,25	6,0	27,9	0,0	19,3	10,0	10,0	0,1
ETE Sepetiba	-		6,1	25,7	0,0	9,0	10,0	10,0	0,1	6,1	26,9	0,0	20,5	20,5	10,0	0,1
ETE Pedra de Guaratiba	-		7,0	26,5	0,0	11,5	16,5	10,0	0,1	7,0	27,5	0,0	21,0	14,0	10,0	0,1
ETE Nova Cidade	-		6,0	27,3	0,1	9,5	13,0	10,0	0,1	6,0	28,0	0,0	2,0	11,5	10,0	0,1
ETE Vila do Céu	-		6,0	23,3	0,0	2,0	21,5	10,0	0,1	6,0	24,1	0,0	6,0	10,0	10,0	0,1
ETE Vilar Carioca	-		6,0	26,3	0,0	9,0	10,0	10,0	0,7	6,0	26,5	0,0	5,0	10,0	10,0	0,2
ETE Vila Catiri	-		6,5	25,2	0,0	16,0	10,0	10,0	0,1	6,5	24,5	0,0	2,0	10,0	10,0	0,1
ETE Ana Gonzaga	-		6,0	26,4	0,0	14,0	31,0	10,0	2,0	6,0	27,7	0,0	11,0	12,0	10,0	0,2
ETE Vila Nova Sepetiba	-		6,2	27,3	0,0	13,0	18,0	10,0	0,1	6,1	27,7	0,0	12,0	10,0	10,0	0,1
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	2	180 mg/L	180 mg/L	30 mg/L	4mg/L	5 - 9	< 40	2	180 mg/L	180 mg/L	30 mg/L	4mg/L
ETE Cidade das Crianças	-		5,7	25,3	0,1	7,0	25,0	10,0	0,1	5,7	24,1	0,0	7,0	10,0	10,0	0,1
ETE Palmares	-		6,0	27,7	0,0	39,0	30,0	10,0	0,2	6,0	29,0	0,0	56,0	40,5	10,0	0,7
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	2	180 mg/L	180 mg/L	40 mg/L	4mg/L	5 - 9	< 40	2	180 mg/L	180 mg/L	40 mg/L	4mg/L
ETE Coqueiro	-		6,0	24,0	0,0	30,0	40,0	10,0	0,2	6,0	25,8	0,1	31,0	21,0	10,0	3,2
ETE Vila Kennedy	-		5,0	22,9	0,0	11,5	10,0	10,0	0,1	5,0	22,5	0,0	6,5	12,0	10,0	0,1
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	1	60 mg/L	60 mg/L	30 mg/L	2mg/L	5 - 9	< 40	1	60 mg/L	60 mg/L	30 mg/L	2mg/L
ETE Areal	-		5,3	26,5	0,0	17,0	10,0	10,0	0,1	6,1	26,9	0,0	2,0	10,0	10,0	0,1
ETE Piaí	-		6,5	25,5	0,0	9,0	10,0	10,0	0,1	6,2	26,3	0,0	9,0	12,0	10,0	0,1
ETE Nova Sepetiba V	-		6,0	26,7	0,0	2,0	12,0	10,0	0,1	6,0	26,5	0,0	6,0	10,0	10,0	0,1
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	2	100 mg/L	100 mg/L	40 mg/L	4mg/L	5 - 9	< 40	2	100 mg/L	100 mg/L	40 mg/L	4mg/L
ETE Vila João Lopes	-		6,3	25,2	0,4	39,0	26,0	10,0	3,3	6,2	26,8	0,4	47,0	43,0	10,0	2,4
ETE São Fernando	-		6,8	24,5	0,7	27,0	28,0	10,0	2,0	6,9	27,2	0,5	54,0	71,0	10,0	3,8

Unidades	Ano de Referência: 2020		Novembro						Dezembro							
	Parâmetros		pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
	Limites		5 - 9	< 40	1	40 mg/L	40 mg/L	30 mg/L	2mg/L	5 - 9	< 40	1	40 mg/L	40 mg/L	30 mg/L	2mg/L
ETE Deodoro	-		6,1	27,4	0,0	17,5	11,5	10,0	0,2	6,0	29,0	0,0	5,8	10,0	10,0	0,1
ETE Sepetiba	-		6,0	25,9	0,0	25,0	16,5	10,0	0,1	6,2	26,9	0,0	21,5	18,0	10,0	0,1
ETE Pedra de Guaratiba	-		7,0	27,4	0,0	12,0	11,0	10,0	0,1	7,0	28,3	0,0	10,0	12,5	10,0	0,1
ETE Nova Cidade	-		6,0	27,0	0,1	10,0	13,0	10,0	0,15	6,0	27,3	0,0	11,0	10,0	10,0	0,1
ETE Vila do Céu	-		6,0	25,0	0,0	8,0	10,0	10,0	0,3	6,0	26,5	0,0	9,5	16,0	10,0	0,2
ETE Vilar Carioca	-		6,0	25,8	0,0	13,5	10,5	10,0	0,2	6,0	26,5	0,0	14,0	10,0	10,0	0,1
ETE Vila Catiri	-		6,5	24,7	0,0	12,0	10,0	10,0	0,1	6,4	25,4	0,0	5,0	10,0	10,0	0,1
ETE Ana Gonzaga	-		6,0	27,2	0,0	9,0	10,0	10,0	0,1	6,3	28,3	0,0	10,0	15,0	10,0	0,2
ETE Vila Nova Sepetiba	-		6,2	26,5	0,0	13,0	15,0	10,0	0,1	6,5	26,4	0,0	2,0	10,0	10,0	0,1
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	2	180 mg/L	180 mg/L	30 mg/L	4mg/L	5 - 9	< 40	2	180 mg/L	180 mg/L	30 mg/L	4mg/L
ETE Cidade das Crianças	-		5,3	25,3	0,0	2,0	19,0	10,0	0,1	5,0	26,6	0,0	2,0	10,0	10,0	0,1
ETE Palmares	-		6,1	27,5	0,0	57,0	60,0	10,0	0,6	6,0	29,7	0,0	39,5	40,5	10,0	0,3
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	2	180 mg/L	180 mg/L	40 mg/L	4mg/L	5 - 9	< 40	2	180 mg/L	180 mg/L	40 mg/L	4mg/L
ETE Coqueiro	-		6,0	24,7	0,0	22,0	15,0	10,0	0,3	6,0	26,2	0,0	37,0	21,0	10,0	0,3
ETE Vila Kennedy	-		6,0	25,0	0,0	9,5	14,0	10,0	0,1	6,2	26,3	0,0	5,5	10,0	10,0	0,1
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	1	60 mg/L	60 mg/L	30 mg/L	2mg/L	5 - 9	< 40	1	60 mg/L	60 mg/L	30 mg/L	2mg/L
ETE Areal	-		5,9	26,1	0,0	24,0	12,0	10,0	0,1	6,2	27,2	0,0	4,0	16,0	10,0	0,1
ETE Piaí	-		6,0	26,2	0,0	13,0	15,0	10,0	0,1	6,0	27,0	0,0	16,0	16,0	10,0	0,1
ETE Nova Sepetiba V	-		6,0	26,7	0,0	7,0	10,0	10,0	0,1	6,0	26,4	0,0	8,0	10,0	10,0	0,1
		Parâmetros	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS	pH	T (°C)	RSS	DBO	SST	O&Gv	MBAS
		Limites	5 - 9	< 40	2	100 mg/L	100 mg/L	40 mg/L	4mg/L	5 - 9	< 40	2	100 mg/L	100 mg/L	40 mg/L	4mg/L
ETE Vila João Lopes	-		6,1	26,3	0,3	36,0	21,0	10,0	2,7	6,2	27,3	0,3	63,0	45,0	10,0	7,5
ETE São Fernando	-		6,6	26,3	0,7	35,0	47,0	10,0	6,0	7,0	26,8	0,3	96,0	83,0	10,0	5,7