

Ofício MA/CGCA/CLA/GLA-4 Nº 1029 / 2016.

Físico - Químico

	Unidades	Parâmetros	pH	T (°C)	RSS	DBO	RNFT	OG	MBAS	
		Limites	5 - 9	< 40	1	40 mg/L	40 mg/L	30 mg/L	2mg/L	
Junho	ETE Deodoro	-	6,0	25,0	0,0	9,0	3,7	<5	<0,1	
	ETE Sepetiba	-	7,0	26,0	0,0	6,0	3,0	<5	<0,1	
	ETE Pedra de Guaratiba	-	7,0	24,0	0,4	7,9	3,0	<5	<0,1	
	ETE Nova Cidade	-	5,3	26,0	0,0	9,0	4,3	<5	<0,1	
	ETE Vila do Céu	-	7,0	25,0	0,0	5,0	1,5	19,0	<0,1	
	ETE Vilar Carioca	-	7,0	28,0	0,0	4,0	2,5	<5	<0,1	
	ETE Catiri	-	6,0	26,0	0,0	4,0	2,0	<5	<0,1	
	ETE Ana Gonzaga	-	7,2	25,0	0,0	10,0	7,9	<5	<0,1	
	ETE Vila Nova Sepetiba	-	7,0	25,0	0,0	12,0	2,5	<5	<0,1	
		Parâmetros	pH	T (°C)	RSS	DBO	RNFT	OG	MBAS	
		Limites	5 - 9	< 40	1	180 mg/L	180 mg/L	30 mg/L	4mg/L	
		ETE Cidade das Crianças	-	6,7	26,0	0,0	5,0	10,0	<5	<0,1
		ETE Coqueiro	-	7,0	21,8	0,1	15,0	21,1	<5	<0,1
		ETE Palmares	-	7,0	27,0	0,0	10,0	4,6	<5	<0,1
		ETE Vila Kennedy	-	6,0	26,0	0,5	142,0	33,3	<5	<0,1
			Parâmetros	pH	T (°C)	RSS	DBO	RNFT	OG	MBAS
			Limites	5 - 9	< 40	1	60 mg/L	60 mg/L	30 mg/L	2mg/L
		ETE Areal	-	7,0	23,8	0,0	2,0	2,5	<5	<0,1
		ETE Nova Sepetiba V	-	6,0	26,0	0,1	14,0	44,0	<5	<0,1
			Parâmetros	pH	T (°C)	RSS	DBO	RNFT	OG	MBAS
		Limites	5 - 9	< 40	1	100 mg/L	100 mg/L	30 mg/L	2mg/L	
	ETE João Lopes	-	6,0	24,0	1,5	13,0	19,2	<5	<0,1	
	ETE São Fernando	-	7,0	23,0	0,0	48,0	37,5	<5	2,4	