

Ofício MA/CGCA/CLA/GLA-4 Nº 1029 / 2016.

Físico - Químico

	Unidades	Parâmetros	pH	T (°C)	RSS	DBO	RNFT	OG	MBAS	
		Limites	5 - 9	< 40	1	40 mg/L	40 mg/L	30 mg/L	2mg/L	
Outubro	ETE Deodoro	-	6,0	27,5	0,0	10,5	7,3	<5	<0,1	
	ETE Sepetiba	-	7,0	27,0	0,0	6,0	8,5	<5	<0,1	
	ETE Pedra de Guaratiba	-	7,0	25,0	0,4	27,0	27,1	<5	1,0	
	ETE Nova Cidade	-	6,1	26,0	0,0	19,0	7,5	<5	<0,1	
	ETE Vila do Céu	-	7,0	25,0	0,1	6,0	3,0	<5	<0,1	
	ETE Vilar Carioca	-	6,0	25,0	0,0	11,0	3,0	<5	<0,1	
	ETE Catiri	-	6,9	28,0	0,0	7,0	3,3	<5	<0,1	
	ETE Ana Gonzaga	-	6,2	25,3	0,0	3,0	6,0	<5	<0,1	
	ETE Vila Nova Sepetiba	-	6,6	24,0	0,0	7,0	2,5	<5	<0,1	
		Parâmetros	pH	T (°C)	RSS	DBO	RNFT	OG	MBAS	
		Limites	5 - 9	< 40	1	180 mg/L	180 mg/L	30 mg/L	4mg/L	
		ETE Cidade das Crianças	-	7,0	27,0	0,0	5,0	0,8	<5	<0,1
		ETE Coqueiro	-	7,0	24,0	0,3	29,0	9,6	<5	<0,1
		ETE Palmares	-	5,4	25,0	0,0	6,0	0,8	<5	<0,1
		ETE Vila Kennedy	-	6,0	26,0	0,0	35,0	12,1	<5	<0,1
			Parâmetros	pH	T (°C)	RSS	DBO	RNFT	OG	MBAS
			Limites	5 - 9	< 40	1	60 mg/L	60 mg/L	30 mg/L	2mg/L
		ETE Areal	-	6,0	26,0	0,0	5,0	6,0	<5	<0,1
		ETE Nova Sepetiba V	-	7,0	26,0	0,0	31,0	22,0	23,0	2,0
			Parâmetros	pH	T (°C)	RSS	DBO	RNFT	OG	MBAS
		Limites	5 - 9	< 40	1	100 mg/L	100 mg/L	30 mg/L	2mg/L	
	ETE João Lopes	-	6,0	29,0	1,6	25,0	29,4	8,0	2,3	
	ETE São Fernando	-	7,0	27,0	0,1	68,0	20,0	<5	2,0	